



How to connect a Horn and Strobe to PureAire LEL monitor

LEL Relay Board



18 AWG, two conductor, stranded control and instrumentation cable, Belden 8461 or equivalent

Federal Signal Horn & Strobe 42002*



This drawing shows how to connect a remote Horn and strobe to PureAire' LEL monitor with the Alarm Relay #1 set to a Normally Open position.

***Note: Federal Signal Horn/Strobe or equivalent**